



LAWRENCE
LIVERMORE
NATIONAL
LABORATORY

US Activities in the Development of Plasma-Based X-ray Lasers

J. Dunn

October 13, 2005

Plasma-based X-ray Lasers: Status and Prospects
Prague, Czech Republic
September 1, 2005 through September 2, 2005

Disclaimer

This document was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor the University of California nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or the University of California, and shall not be used for advertising or product endorsement purposes.

Plasma-based X-ray lasers

Status and Prospects

US Activities in the Development of Plasma-Based X-ray Lasers


James Dunn

Lawrence Livermore National Laboratory



Presented at the:

“Plasma-Based X-ray Lasers: Status and Prospects” Workshop
Prague, Czech Republic 1 - 2 September, 2005



Work performed under the auspices of the US Department of Energy by the University of California Lawrence Livermore National Laboratory under Contract No. W-7405-Eng-48 and in part by funding from the National Science Foundation through the Center for Biophotonics, an NSF Science and Technology Center, managed by the University of California, Davis, under Cooperative Agreement No. PHY 0120999.

Acknowledgments to contributions, information and discussions with numerous people:



Camille Bibeau	(LLNL)
John Caird	(LLNL)
Jorge Filevich	(Colorado State University)
Roisin Keenan	(LLNL)
Rich London	(LLNL)
Steve Moon	(LLNL)
Art Nelson	(LLNL)
Joe Nilsen	(LLNL)
Prav Patel	(LLNL)
Yuan Ping	(LLNL)
Jorge Rocca	(Colorado State University)
Ronnie Shepherd	(LLNL)
Slava Shlyaptsev	(UC Davis)
Ray Smith	(LLNL)
Szymon Suckewer	(Princeton University)
Franz Weber	(LLNL)
Philippe Zeitoun	(LOA)



Outline:


- **Historical Perspective for US X-ray Laser Effort**
 - Nova X-ray laser effort (1984 - 1996)
 - Achievements and applications
 - Recombination scheme at Princeton University
- **Developments in various US laboratories and schemes (- 1999)**
- **Review of present US status (2000 - 2005)**
 - Source development
 - Characterization
- **X-ray Laser Applications (Round Table discussion 9/2/05)**
- **Future trends: Laser drivers for x-ray lasers**
 - High Energy, High Peak Power, High Repetition Rate
 - High Peak Power: Titan at LLNL
 - High Repetition Rate: Mercury DPSSL

Historical Perspective:



- Nova X-ray laser effort (1984 - 1996)
- Achievements and applications
- Recombination scheme at Princeton University

Early effort 1984 - 1996 on x-ray lasers was performed on the Nova laser: collisional excitation scheme was developed



Large scale Inertial Confinement Fusion driver used for first experiments: Main laser amplifier bay




Exploding foil target and x-ray laser was designed after substantial modeling and experimental characterization effort




Ne-like Se Simplified Level Diagram

$n_e = 5 \times 10^{20} \text{ cm}^{-3}$
 $T_e = 1 \text{ keV}$



- 2-D LASNEX hydro simulations combined with XRASER atomic kinetics code (100s of levels included)
- Gain on following lines: 18.3, 20.6, 20.9 nm

Density Profile Measurements






- Exploding Se foil compared with 2-D LASNEX simulations for laser irradiation conditions (n_e density profile)
- T_e ionization conditions measured

Ne-like Se laser at ~ 20 nm was first demonstration of collisional excitation x-ray laser in 1984 on Novette



- Exploding foil Se target
- 1 kJ, 450 ps 2ω each side
- Line focus $200\ \mu\text{m} \times 1.1\ \text{cm}, 2.2\ \text{cm}$
- Double and single-sided irradiation



- Lasing observed on Ne-like Y transitions
- Lasing observed on Ne-like $3p - 3s\ J = 2 - 1$ lines at 20.63 and 20.96 nm
- $g \sim 5\ \text{cm}^{-1}$, $gL = 6.5$
- No lasing observed on 18.3 nm $J = 0 - 1$ line





Further achievements with Nova x-ray laser:

- **Wavelength scaling for Ne-like ion x-ray lasers to 10 nm (Fields 1992)**
- **Demonstration of Ni-like ion XRLs Eu 6.6, 7.1 nm (MacGowan 1987)**
- **Double-pass XRL amplifiers using multilayer optics (Ceglio 1988)**
- **X-ray laser holography demonstration (Trebes 1988)**
- **X-ray laser coherence measurements (Trebes)**
- **Shortest wavelength XRL Ni-like Au 3.5 nm (MacGowan 1990)**
- **High peak power measurements (Da Silva et al 1993)**
- **Line width measurements (Koch 1992)**
- **Hyperfine splitting Ne-like Nb 14.59 nm (Nilsen 1993)**
- **Use of pre-pulse to improve XRL generation (Nilsen 1993)**

Applications using the Nova-driven x-ray laser:





XRL Radiography Imaging of laser-heated Al Foil





R. Cauble et al, PRL 74, 3816 (1995)

XRL Interferometry of Laser Plasmas



Da Silva et al, PRL 74, 3991 (1995).

X-ray Laser Microscopy of Biological Cells at 4.5 nm



L. Da Silva et al.,
Science 258, 269 (1992)



Recombination Carbon 18.2 nm laser at Princeton based on a magnetically confined plasma column 1984 - 1985

VOLUME 55, NUMBER 17

PHYSICAL REVIEW LETTERS

21 OCTOBER 1985

Amplification of Stimulated Soft-X-Ray Emission in a Confined Plasma Column

S. Suckewer, C. H. Skinner, H. Milchberg, C. Keane, and D. Voorhees
Plasma Physics Laboratory, Princeton University, Princeton, New Jersey 08544
(Received 1 March 1985)

An enhancement of ~ 100 of stimulated emission over spontaneous emission of the C VI 182-Å line (one-pass gain ~ 6.5) was measured in a recombining, magnetically confined plasma column by two independent techniques involving intensity-calibrated extreme-uv monochromators. Additional confirmation that the enhancement was due to stimulated emission has been obtained with a soft-x-ray mirror; with 12% measured effective reflectivity of the mirror, a 120% increase in intensity of the C VI 182-Å line in the axial direction was observed.




FIG. 1. Scheme of experiment with a carbon-disk target with a $0.8 \times 4\text{-mm}^2$ horizontal slot and with a thin carbon blade 2 cm long.




FIG. 2. Time evolution of C VI 182-Å and 135-Å line intensities measured with axial and transverse xuv instruments for two discharges with the same plasma condition. The enhancement for the 182-Å line was $E \approx 100$; the on pass gain was $kl \approx 6.5$.






FIG. 3. Experimental setup with xuv spherical mirror.





Pumped with 0.3 kJ, 80 ns CO₂ laser
gL ~ 8 for 18.2 nm $n = 3 - 2$ H-like C

Recombination carbon x-ray laser applications: 18.2 nm soft x-ray reflection microscopy of biological cells (1992 - 1995)



Biological Cells



High density memory chip

SXL Reflection
microscope



Optical
microscope

Other US X-ray Laser Research in 1980s and 1990s



- **Summary of activities in different US laboratories**
- **X-ray laser schemes**
- **Highlights of x-ray laser research**



Other laboratories in 1980s and 1990s:

- **Collisional Excitation:**

Using smaller lasers, 1ω , slab targets:

- 200 J, $\sim 1 - 2$ ns class lasers

- Naval Research Lab. (Elton, McLean): Ne-like Cu - Se - **1992**

- NRC Canada (Baldis, Enright): Ne-like Ge, Ni-like Sn **1989 - 1992**

- Tabletop 100 ps lasers

- MIT (Hagelstein): Ni-like Nb **1988 - 1990s**

- Capillary Discharge - Colorado State University (Rocca) **~ 1992 -**

- Utah (Knight)

- Tabletop 1 ps lasers LLNL (Dunn, Nilsen, Osterheld, Shlyaptsev) **1997-**

- **Recombination Laser-driven:**

- U. Maryland (Griem, Moreno) Al, Mg

- LLNL Nova Al 20 ps drive

- U. Rochester (Richardson)

- Colorado State University (Rocca) C, F, O - **1992**










Other laboratories and x-ray laser schemes

- Resonant Photo-pumping: **Not demonstrated**
 - NRL (Apruzese, Davis) 1985 Z-pinch Na X - Ne IX
 - LLNL (Nilsen) many schemes proposed
 - U. Rochester (Boehly) Ne-like Ti
 - Sandia Nat. Lab. (Matzen, Porter) Z-pinch Na X - Ne IX
 - U. Cornell (Hammer) Z-pinch
- Innershell: **Some earlier work in UV by Silfast (1983), Kapteyn (1980s)**
 - U. San Diego (Barty, Kim, Toth) electron pumped various XRLs
 - LLNL (Eder, Moon, Weber, Celliers) photo-ionized C K- α 4.5 nm
- Optical Field Ionization (OFI):
 - Collisional Excitation
 - U. Stanford (Lemoff, Barty, Harris) Pd-like Xe 41.8 nm **1995**
 - Recombination
 - Princeton (Korobkin, Suckewer) Li Ly- α 13.5 nm **1996**

Capillary Discharge: Amplification in Ne-like Argon at 46.9 nm

- Exponential amplification of the $3p^1S_0 - 3s^1P_1$ line creates a bright single line laser source at 46.9nm
- Gain saturation achieved for 15cm plasma column lengths



J. J. Rocca et al., PRL 73, 2192 (1994); PRL 77, 1476 (1996).

Tabletop capillary discharge laser produces similar coherent average power at $\lambda=46.9$ nm as synchrotron

Capillary discharge 46.9 nm laser

- High average power: 1-3 mW
- High pulse energy: 0.1 mJ – 0.8mJ @4 Hz
- Narrow spectral bandwidth: $\Delta\lambda/\lambda = 10^{-4}$
- Beam directionality: $\theta = \sim 5$ mrad

Highest average power compact coherent SXR light source available




B. Benware et al., PRL 81, 5804 (1998); C.D. Macchietto et al., Opt. Lett. 24, 1115 (1999).

Optical Field Ionization process was demonstrated for collisional x-ray lasers using inert gas medium at Stanford



- OFI/collisional scheme proposed by Burnett and Corkum 1989.
- Gas is stripped by tunneling ionization by laser electric field to create desired ion state
- Energetic electrons collisionally pump ground state to create inversion
- 40 fs, 70 mJ, 10 Hz, $3 \times 10^{16} \text{ W cm}^{-2}$
- Xe gas cell, longitudinally pumped
- $g \sim 13 \text{ cm}^{-1}$, $gL = 11$, Pd-like Xe
- OFI collisional x-ray lasers have been driven into gain saturation regime recently by LOA group for Xe and Kr

Pd-like Xe 5d - 5p x-ray laser at 41.8 nm wavelength




B.E. Lemoff et al, PRL 74, 1574 (1995)




Optical Field Ionization was also demonstrated for recombination Li III 2 - 1 13.5 nm x-ray laser at Princeton

Experimental Geometry



H-like Li Ly- α 13.5 nm x-ray laser




Korobkin et al, PRL [77](#), 5206 (1996)

- $g \sim 11 \text{ cm}^{-1}$, $gL = 5.5$
- Experiment repeated at NRL using capillary discharge



Basics of Inner-shell Photo-ionized x-ray laser:



USPL (< 50 fs FWHM) @ > 1 J produces a hot plasma at line focus.


Plasma generates a broad-band x-ray spectrum with a rapid rise time.

A high-pass filter rejects a majority of low energy x-rays that can populate the lower state.

Remaining harder x-rays primarily photo-ionize inner-shell of lasant atoms.


- **Proposed by Duguay and Rentzepis (1967)**
- **Modeling for C by (Eder, Moon), experimental activities by Weber and Celliers**

Competing Basic Atomic Processes Provide Challenge for ISPI Lasing In Carbon



- The filtered pump produces a population inversion, and resulting positive gain for an allowed 2p-1s radiative transition in the singly charged ion.
- Rapid Auger decay of the 1s hole state competes with the lasing transition and produces a large number of energetic electrons into the lasant material.
- Electron induced ionization to the lower laser state ($1s^2 2s^2 2p^1$) limits the magnitude and duration of positive gain.
- Ultra-short pulse x-ray lasing is inherent in this scheme.

Tabletop Transient 1 ps x-ray laser work at LLNL started in 1997 - motivated by Ne-like Ti results at MBI group in Berlin



Compact Multipulse Terawatt (COMET) laser has 4 beams of 0.5 - 600 ps pulse duration available simultaneously for experiments

Transient scheme uses 1 ps, 5 - 10 TW laser pulse to optimize excitation - Tabletop X-ray Laser




Two Stage Process

Long laser pulse: **1 - 5 J**


- plasma formation
- ionization
- delay for relaxation of density gradients

Short laser pulse: **2 - 7 J**

- excitation



Tabletop



Laser
Driver

Optimize Excitation

- Pump energy: <10 J, $\sim 2 - 7$ J
- High gain: $25 - 65 \text{ cm}^{-1}$
- Target length: $\sim 1 \text{ cm}$
- Wavelength: 119 \AA (104 eV)
- High shot rate: 1 shot/4 min.
50-100 shots/day
- XRL duration: $3 - 7 \text{ ps}$
- Inexpensive slab targets

P.V. Nickles *et al*, PRL 78, 2748 (1997)


Yu. V. Afanasiev and V.N. Shlyaptsev, Sov. J. Quant. Electron. 19, 1606 (1989).

10 - 1000x reduction in laser energy for transient scheme compared to Nova x-ray laser

Traveling wave drives Ni-like Pd at 14.7 nm into gain saturation regime with 5 - 7 J energy in line focus




Ni-like Pd gain with traveling wave



J. Dunn, Y. Li, A.L. Osterheld, J. Nilsen, J.R. Hunter, V.N. Shlyaptsev, Phys. Rev. Lett **84**, 4834 (2000)

- Small signal gain of 41 - 62 cm^{-1}
- 100x enhancement with TW
- $gL = 18$, output energy $\sim 12 \mu\text{J}$
- 0.5 - 1.5 J, 600 ps , 4.5 - 5.5 J, 1.3 ps

Ni-like x-ray lasers and Pd angular pointing



- Radex simulations indicate maximum deflection angle $(n_e/n_c)^{0.5}$ reveals optimal amplification at $n_e \sim 0.9 \times 10^{20} \text{ cm}^{-3}$

Higher efficiency of Ni-like XRL well matched to small driver


Output still increasing with length - **extract more XRL energy**

Recent highlights of present US status (2000 - 2005)



- **Grazing Incidence Pumping**
- **Source development capillary discharge**

Grazing Incidence Pumping (GRIP): Novel method for efficient x-ray lasers uses controlled refraction of pump




- Two stage pumping process to generate x-ray laser
- Short pulse propagates in plasma up to a specific electron density and selectively pumps the active volume for the gain region
- Short pulse is then refracted back into gain region
- Short pulse angle given by $\theta = \sqrt{n_{e0}/n_{ec}}$ where n_{e0} = density at turning point
- Traveling wave pump inherent and no restriction on target length
- Absorption efficiency of 5-8% for transverse increases to 50-70% for GRIP

Ni-like Mo 18.9 nm, 10 Hz x-ray laser demonstrated using 150 mJ of 800 nm laser energy




Spectrometer: Wavelength, Refraction and Divergence Angle



4.5 mrad deflection angle
3 mrad (FWHM) beam divergence

Imaging XRL with multilayer optics: exit size, beam line reproducibility




Mo:Si multilayers courtesy of J. Nilsen, T.W. Barbee, Jr.

XRL has good characteristics but sensitive to pump laser overlap

Pumping conditions optimized to maximize Ni-like Mo 18.9 nm x-ray laser output




Delay between laser pulses with modeling



Plasma produced by narrow $15\ \mu\text{m}$ LP line focus strongly affects window for optimized lasing

XRL output shows saturation-like behavior at 4 mm

SP = 1.5 ps, $\Delta t = 500$ ps



R. Keenan et al, *Phys. Rev. Lett.* **94**, 103901 (March 2005)

gl~14 operating close to saturation

Estimated XRL output of >10 nJ


High XRL gain observed for very small laser energy pump and experimental delay between pulses in agreement with simulations

GRIP scheme transferred to COMET for x-ray laser wavelength scaling with $\sim 1 - 2\text{J}$ laser drive




Ni-like Pd 14.7 nm output vs LP-SP delay

Pd 4 mm target



XRL output vs length

$\Delta t = 200\text{ps}$



XRL spectrum and pump conditions


Laser Pump Conditions

LP (1ω): 1.2 J, 1054 nm, 600 ps

SP (2ω): 1.3 J, 527 nm, 1.5 ps

θ : 10° $n_e \sim 1.2 \times 10^{20} \text{ cm}^{-3}$

X-ray Filter: 2000Å Al




- GRIP x-ray laser works well for different Z, laser pump conditions
- 10x more pump energy gives >100x more output



Scaling x-ray laser to short wavelengths requires higher power laser pump, $P \sim \lambda_{\text{XRL}}^{-(4-6)}$



RADEX Predicted Parameters for GRIP X-ray Laser



Z	λ_{XRL} (nm)	λ_{pump} (nm)	E_{pump} (J)	n_e (10^{20} cm^{-3})	Status
Mo	18.9	800	0.15	1	✓
Pd	14.7	527	0.4 - 3	1 - 2	✓
Nd	8.0	527	9 - 12	5	Laser time?
Ta	4.5	?	50?	>5?	Laser*


 X-ray Laser Wavelength
  Laser Pump Wavelength

- GRIP pumping will reduce laser pump energy requirements by orders of magnitude to generate efficient x-ray laser
- Tentative extrapolation into water-window

Laser* depends on Titan ~2005

Plan to continue to study intermediate sub-10 nm XRLs

Lasing observed at wavelengths as short as 10.9 nm





Gain saturated
operation
demonstrated


J.J. Rocca et al. SPIE Conf.
Proc. Vol 5919

Y. Wang et al. submitted
Phys. Rev. A

Gain-saturated Ni-like 13.2 nm Ni-like Cd laser

1 J short pulse – 23 degrees grazing incidence angle






*Similar performance also obtained for Ni-like Cd
@ 13.2 nm, $> 1 \mu\text{W}$ average power*





High repetition rate desk-top EUV laser

The laser occupies a table surface area of 0.4 m^2



S. Heinbuch et al., Optics Express, **13**, 4050, (2005).

Desk-top 46.9 nm laser output pulse statistics 1500 shots at 12 Hz repetition rate




X-ray Laser Applications




- **Capillary Discharge - Various Applications**
- **Picosecond Transient - Photoelectron spectroscopy**
- **Plasma characterization - 14.7 nm interferometry**
- **Biological Imaging**

Table-top capillary discharge Soft X-ray lasers have been used in numerous applications


1. Interferometry of laser-created plasmas




2. EUV microscopy




3. Nanopatterning



4. Laser Ablation





5. Nanocluster Spectroscopy



1. J.J. Rocca et al, Phys. Of Plasmas, **10**, 2031 (2003).
2. F. Brizuela et al, Optics Express, **13**, 3983, (2005)
3. M.G. Capeluto et al, IEEE Transactions on Nanotechnology, (in press),
4. J. Juha et al, Appl. Phys. Lett. **86**, 034109 (2005).- M. Grisham et al, Optics Letters, **29**, 620 (2004).


Applications of capillary discharge soft x-ray lasers



I.A. Artiukov et al., IEEE J. Selected Topics in Quantum Electron. 30, 328 (2000).




Soft x-ray interferometry laser interferometry



Soft x-ray laser interferometry of laser-created plasmas maps two-dimensional dynamics that differs from classical expansion **Colorado State University**




Line-focus plasma 1.8 mm long (*J. Filevich et al. Phys. Rev E, 67, (2003)*)

Magnification 25 x, $I = 0.1 \text{ TW/cm}^2$, $l = 1.06 \text{ mm}$, 13 ns FWHM pulse width




High resolution imaging with 46.9 nm capillary discharge laser: 120-140 nm Resolution

Images of a zone plate



~ 94 % modulation >> 26.5 % (Rayleigh-like modulation)




Time-of-Flight Photoelectron Spectroscopy requires picosecond pulsed source (84.5 eV x-ray laser photons)



Measure electron kinetic energy by time-of-flight technique

$KE = h\nu - BE - \phi_s$, Binding energy BE, work function ϕ_s

- COMET Ni-like Pd X-ray laser photoionizes surface atoms
- Extracted shallow core-level and VB photoelectrons have velocity distribution (kinetic energy distribution ≤ 84.5 eV)
- Time-of-flight (ToF) spectrometer used to energy analyze photoelectrons
- Electrons travel through drift tube detected by micro-channel plate (MCP) and fast digitizer
- Capable of high energy resolution with high throughput




We probe changes in electronic structure during the dynamic processes of melting



COMET pump-probe experiment with e-ToF PES and soft x-ray radiography

An optical pump melts the material, and the electronic structure is probed after a time Δt by X-ray laser induced photoelectron spectroscopy

Optical Pump - X-ray laser Probe Experimental Layout




1. Foil or pinhole isolates x-ray laser beam line vacuum from UHV chamber
2. Optical beam fluence of $\sim 500 \text{ mJ/cm}^2$ will produce melt - 5 - 50 mJ in 1 mm spot

Dynamic x-ray laser photoelectron spectroscopy of the valence band electronic structure of heated materials has been demonstrated

Simultaneous measurement of the electronic structure and opacity of 50 nm Cu foils



- Pump 527 nm, 400 fs laser, 0.1 – 2.5 mJ energy in 500 x 700 μm^2 (FWHM) spot.
- Heating with $0.07 - 1.8 \times 10^{12} \text{ W cm}^{-2}$ intensity
- Cu *d* band emission evident in valence band



Single-shot e-ToF normal emission spectra of static and laser heated ultrathin Cu foil

decreasing Cu 3*d* peak intensity due to depopulation of the *d*-band as the electron temperature T_e increases

creates vacancies in the CB – interband absorption below the edge 3*d*-4*p* transitions


Cu 3*d* peak shifts towards lower kinetic energy (higher binding energy) – band is ‘sinking’.

no broadening of the Cu 3*d* upon heating – nonequilibrium distribution of occupied states

14.7 nm, ps duration soft x-ray laser interferometry at LLNL used to probe hot dense laser-produced plasmas




14.7 nm Diffraction Grating Interferometer



- X-ray laser interferometry of laser produced plasma shows interesting phenomena - formation of on-axis dip
- Fringe reversal observed at late time produced by Al^{1+} - Al^{5+} bound electrons effect on plasma refractive index

Al plasma heated at $10^{13} \text{ W cm}^{-2}$ probed at various times



22x magnification images
~4.5 ps snapshot



In collaboration with
Jorge Rocca, CSU

J. Filevich, J.J. Rocca, et al., "Observation of a multiply ionized plasma with index of refraction greater than one", Phys. Rev. Lett., 94, 035005 (2005)

X-ray laser beam is characterized for interferometry: coherence and fringe visibility with 4 - 6 ps duration




XRL Coherence and Fringe Visibility



R. F. Smith *et al.*, Opt. Lett. 28, 2261 (2003).

XRL Pulse vs SP duration




With R. Shepherd, R. Booth

- (a) Excellent spatial coherence - high fringe visibility 0.72 ± 0.12
- (b) Excellent longitudinal coherence - Michelson interferometry (With P. Zeitoun, S. Hubert et al LIXAM/CEA)
- (c) X-ray laser pulse duration 4 - 6 ps (FWHM) for interferometry

XRL interferometry shows features close to target surface: density dip on-axis observed n_e



Al targets heated by 3 J, 12 μm wide, 600 ps pulse at $>10^{13} \text{ W cm}^{-2}$




- Previously, flat targets irradiated at below $10^{12} \text{ W cm}^{-2}$ have low n_e due to strong 2-D effects
- Observe $n_e > 4 \times 10^{20} \text{ cm}^{-3}$ at +0.6 ns for flat target
- Plasma pressure gradients, radiative heating and thermal conduction produces dense plasma in side lobes

* Long 12 ns heating expt.

J. Filevich, J. J. Rocca *et al*,
“Two dimensional effects in laser-created plasmas measured with soft-x-ray laser interferometry”, *Phys. Rev. E* 67, 056409 (2003).

On axis dip, formation of side lobes also observed recently*

Experimental interferograms used for comparison with 2-D LASNEX simulations



Further investigation of this phenomena is in process

Re-visit 4.5 nm x-ray laser biological imaging conducted on Nova in 1992 with smaller drive



Biological Imaging Setup Using Zone Plate Objective and Image




Image of rat sperm, partially hydrated, stained with anti-protamine 2 antibodies and labeled with 40-nm gold microspheres.

Fine details observed in inner wall with ~50 nm scale

Promise of wet-cell imaging - no perturbation

High contrast possible in different cell structure (DNA, protein)

L. Da Silva *et al.*, *Science* **258**, 269 (1992)

Constraints:

1. Big laser 3 - 10 kJ required for Ni-like Ta x-ray laser e.g. Nova or Gekko XII
2. Repetition rate was low - limited shots
3. Source development to improve output and repeatability
4. Expensive - e.g. present day NIF \$200k/shot

Primary goal is to develop a new high efficiency $E_{\text{pump}} < 200 \text{ J}$ laser-pumped, sub-ps x-ray laser that will work in the water-window

In collaboration with UC Davis Center for Biophotonics, Science and Technology

Future trends: Laser drivers for x-ray lasers



- **High Energy, High Peak Power, High Repetition Rate**
- **High Peak Power: Titan at LLNL**
- **High Repetition Rate: Mercury DPSSL**

Laser Drivers: High Energy, High Power and High Repetition Rate, Ultrafast lasers have different applications for XRLs




- High Energy
 - NIF (LLNL) 1.8 MJ, 192 beams **under construction**
 - OMEGA (LLE - U. Rochester) 40 kJ, 60 beams
 - Z-Beamlet (SNL) 0.5 kJ 2ω , 250 ps
 - Janus (LLNL) 1 kJ, 1ω , 3 ns
 - Trident (LANL) 50 - 250 J 2ω , 100ps - 3 ns, 2 beams, + 20 - 40 TW SP
- High Power
 - OMEGA EP (LLE - U. Rochester) 2.6 PW, 2.6 kJ, 1 ps **under construction**
 - Titan (LLNL) ~ 1 PW, 350 J, 0.4 ps
 - U. Texas Petawatt 1.3 PW, 200 J, 150 fs, **under construction**
 - Z-Beamlet Petawatt (SNL) 1 PW, 500 J, 0.5 ps **under construction**
 - Hercules (U. Michigan, CUOS) 45 TW, 27 fs
 - XRL** - COMET (LLNL) 15 TW, 7.5 J, 0.5 ps, 5 J, 600 ps
 - ALLS (Quebec, Canada) 20 TW, 100 TW, U. Nevada, Reno, U. Ohio,
- High Repetition Rate (mainly Ti:Sapphire)
 - XRL** - Callisto (LLNL) 0.15 J, 130 fs, 10 Hz GRIP
 - UC Berkeley (Leemans) 4 J, 30 fs, 10 Hz
 - XRL** - CSU (Rocca) 1 J, 2 ps, 10 Hz
 - Falcon (LLNL) 0.5 J, 30 fs, 2 Hz
 - Mercury (LLNL) DPSSL 55 - 100 J, 10 Hz, 10 ns (**short pulse being considered**)
 - U. Colorado, 1.1 mJ, 28 fs, 10 kHz, U. Princeton

JANUS Laser system recently upgraded to 1kJ/beam CPA Titan upgrade to install short pulse arm in 2005




JANUS Upgrade Laser 2003/4



- Uses NIF type oscillators
- Maximum energy 1 kJ, 1054 nm in 15 cm beam 3 ns
- 100 J, 527 nm, 6 ns used to pump Callisto 200 TW, 80 fs

CPA TITAN 2005



- Uses NIF PW parts
- Titan staged implementation
- Phase 1: 150 J, 0.5 - 200 ps
1 kJ, 3 ns long pulse

LLNL Titan Laser Specification




Current Upgrade:

- ❑ 1 short-pulse, 25 cm dia, 350J in 400 fs, 1 shot/30 min.
- ❑ 1 long-pulse, 14 cm dia, 1 kJ @1 ω , or 600 J @2 ω , 3ns
NIF pulse-shaping capability

Not to Preclude:


- ❑ Install 2nd CPA arm in compressor
- ❑ Independent ps probe beam ~ 100 mJ @2 ω or 3 ω
- ❑ Adaptive Optics
- ❑ Frequency doubling

Titan Laser Target Area: Vacuum Compressor Box and Target Chamber



From Prav Patel

Titan Target Chamber: First experiments configured for short pulse only - many options for long pulse beam



From Prav Patel

09-01-05-XRL-JD-42


Titan first-light was June 2005 (50 J in 0.5 ps) - First experiment will be begin in September 2005




Compressor & Optics Installation




World's largest MLD gratings







New multi-beam target chamber



The Mercury Laser is the first step toward building a MW, 10 Hz class of IFE lasers - Diode Pumped Solid State Laser (DPSSL)




Mercury was operated for 55 J at 10 Hz for $> 10^5$ shots with both amplifiers deployed - use He gas cooling



$\lambda = 1047 \text{ nm}$
 $4.2 \times 7.2 \text{ cm}^2$ beam
 2ω operation 22 J, 10 Hz

Mercury currently being considered for long pulse experiments in next 6 - 9 months



Short pulse architecture and capability being considered now - x-ray laser source applications would be a good match



Summary:

- **Nova X-ray laser effort initiated 20 years ago**
- **Smaller facilities over the years have improved collisional excitation lasers at lower cost**
- **Potential for re-investigating some x-ray lasers OFI/Recombination, ISPI schemes using ultrafast, high peak power lasers**
- **Development of x-ray laser applications highly dependent on robust output with careful characterization and optimization**
- **Future Laser drivers for x-ray lasers will combine properties of**
 - **High Peak Power, High Repetition Rate**
- **Still a niche for bigger single shot facilities where total x-ray laser photon number is important.**